



Energy, Exergy and Thermo-economic Analysis of the Novel Combined Cycle of Solid Oxide Fuel Cell and Biogas Steam Reforming for Cogeneration Power and Hydrogen

E. Soleymani Afsooran, S. Ghavami Gargari, H. Ghaebi*, S. Basiri Anzabi

Department of Mechanical Engineering, Mohaghegh Ardabili University, Ardabil, Iran

ABSTRACT: In this paper, a new configuration of a solid oxide fuel cell/gas turbine combined cycle system with a biogas reforming cycle is presented for the purpose of coproduction production of power and hydrogen. The heat output from the base system of the solid oxide fuel cell/gas turbine is used to supply the energy required for the reforming reaction and to drive the biogas reforming cycle for hydrogen production. Comprehensive thermodynamic and thermo-economic modeling has been performed using engineering equation solver software. Also, the parametric study has been analyzed for the effect of different parameters on the net output power, energy and exergy efficiency, exergy destruction rate, and the sum unit cost products of the whole system. The results show that the energy efficiency and exergy efficiency of the proposed combined system have increased the comparison of the solid oxide fuel cell/gas turbine system by 23.31% and 28.19%, respectively. The net output power and hydrogen production rate are obtained at 2726 kW and 0.07453 kg/s, respectively. From the exergy viewpoint, the afterburner causes a considerable amount of exergy destruction for the system by approximately 26% of the total exergy destruction rate. By increasing the inlet temperature fuel cell, the cell voltage reaches a maximum value at a temperature of 679 K and then decreases. As a result, energy and exergy efficiency are maximized and then reduced. Besides, the total exergy destruction rate and sum unit cost product of the cogeneration system is calculated equals to 1532 kW and 9400 \$/GJ, respectively.

Review History:

Received: Nov. 13, 2020
Revised: Jul. 10, 2021
Accepted: Sep. 04, 2021
Available Online: Sep. 27, 2021

Keywords:

Cogeneration system
Oxide fuel cell
Steam reforming
Energy and exergy.

1- Introduction

Increasing energy consumption, due to the rapid development of commercial divisions and population increase, was amplified substantially in recent years [1]. Accordingly, to address the further required power, various plants were conspicuously developed [2]. However, these power plants utilize fossil fuel resources that produce greenhouse gas emissions like Carbon dioxide, resulting in Ozone layer diminution and global warming. Consequently, some restrictions, such as enacting the Kyoto and Montreal protocols, were taken into account to reduce air contamination [3]. In this regard, the development of renewable energy resources attracted attention globally. Thus, fuel cells and the hydrogen industry can address multiple problems that arise with conventional energy conversion systems.

Since solid oxide fuel cells operate in normal pressure conditions, high-pressure Solid Oxide Fuel Cells (SOFCs) can be utilized to produce high-temperature exhaust gases that can be further delivered to gas turbines for producing electricity. In combined Solid Oxide Fuel Cell/Gas Turbine (SOFC-GT) cycles, the exhaust gases of SOFC are directly inserted into the gas turbine in a high-pressure and high-temperature state. Campanari et al. [4] showed that the integration of a solid oxide fuel cell with a gas turbine has a relatively higher efficiency

*Corresponding author's email: hghaebi@uma.ac.ir

than the combined cycle of a steam turbine. However, they report an ultimate efficiency of more than 75% for both systems, while Whiston et al. [5] reported an electric efficiency of 9.52% for the same gas turbine combined cycle.

The utilization of biogas to generate hydrogen based on the reforming processes has become an attractive technology for small-scale locally distributed units. In the biogas and are the basic elements, where the dry reforming process can be the most appropriate option to generate hydrogen [6]. Among various processes, Steam Methane Reforming (SMR) is the most prevalent chemical process in converting methane into hydrogen with water to methane ratio of 1:1. A biogas steam reforming system is proposed by Cipiti et al. [6] in a temperature range of 700- 900, where theoretical and empirical studies are performed. Based on their results, the increment of the temperature and steam-to-carbon molar ratio can improve the hydrogen generation rate.

2- Methodology

Comprehensive thermodynamic and thermo-economic modeling has been performed using Engineering Equation Solver (EES) software. Also, a parametric study has been performed to demonstrate the effect of different parameters on the main performance metrics of the devised system.



3- Results and Discussion

In this part, the obtained results of the energy, exergy, and exergoeconomic analyses for the devised Solid Oxide Fuel Cell/Gas Turbine/ Biogas Steam Reforming (SOFC-GT-BSR) are presented based on the design conditions, assumptions, and governing equations.

It consists of two major subsystems, each of which is validated separately with the related publication. Therefore, the obtained results of the SOFC unit are compared with the work of Sadat et al. [7] and Ma et al. [8]. It can be seen that there is a good agreement in the present work with the mentioned reference. Also, the data acquired by Ma et al. [8] were used to assure the validity of the obtained data for the SOFC simulation. The comparisons of voltage variation, as well as the power density between the present study and the one conducted by Ma et al., are depicted in Fig. 2. In these comparisons, the SOFC inlet pressure is considered to be equal to that of ambient pressure. It is evident that an acceptable agreement is witnessed.

Furthermore, the main results of the SOFC-GT-BSR system are presented which shows the energy efficiency of the hybrid SOFC-GT-BSR system is improved from 52/28% to 64/47% compared to the stand-alone SOFC-GT unit; thus, from the first-law viewpoint, the integrated system provides competent results. Moreover, the exergy efficiency of the proposed combined system can be enhanced from 50/43% to 64/65%, which indicates that the combination of systems provides higher exergetic efficiency rather than stand-alone systems. Besides, SOFC electrical power, net output electrical power, and hydrogen mass flow rate are obtained 2424 kW, 2726 kW, and 0/07453 kg/s, respectively. Furthermore, the total exergy destruction rate and Sum Unit Cost of the Product (SUCP) of the cogeneration system are calculated as 1532 kW and 9400 \$/GJ, respectively. The highest exergy destruction rate among all components of the system belongs to the afterburner with a rate of 404/8 kW followed by gas turbine and SOFC stack with values of 302/6 kW and 158/7 kW, respectively. Also, the effect of major operating parameters such as current density, SOFC inlet temperature, carbon dioxide to methane molar ratio, steam to carbon molar ratio, and reformer temperature on the performance of the SOFC-GT-BSR integration is analyzed to provide a better understanding of the system's performance.

4- Conclusion

In the present work, a combined system based on a combination of solid oxide fuel cell (SOFC) with Biogas-Steam Reformer (BSR) driven by renewable energy resources (and) was investigated from the energy, exergy, and exergoeconomic perspective. The major goal of this system is to recover the wasted energy of SOFC-GT for hydrogen production within the BSR system with minimum environmental effects. A precise model of the reference concept was developed employing Engineering Equation Solver (EES). Based on the developed model, a detailed thermodynamic and economic analysis were performed. Also, the parametric study of the hybrid system has been performed to investigate the effect of different parameters on the target functions, which include SOFC voltage, net

output power, energy, and exergy efficiency of SOFC and combined system, hydrogen mass flow rate, and the Sum Unit Cost of Products (SUCP) of the whole system and among the examined parameters, SOFC inlet temperature and compressor pressure ratio are the most important parameters that affect the performance of the SOFC and BSR units. In this regard, the significant results are listed as follows:

The energy efficiency of the hybrid SOFC and BSR system is improved by 23/31% from 52/28% to 64/47% compared to the stand-alone SOFC-GT unit.

The exergy efficiency of the combined SOFC and BSR system can be enhanced by 28/19% from 50/43% to 64/65%, which indicates that the combination of systems provides higher exergetic efficiency rather than stand-alone SOFC-GT system.

SOFC electrical power, net output power, and hydrogen mass flow rate are computed as 2424 kW, 2726 kW, 0/07453 kg/s, respectively.

Afterburner contributed to the highest exergy destruction rate among all components of the system with a rate of 404/8 kW followed by gas turbine and SOFC stack with values of 302/6 kW and 158/7 kW, respectively.

The highest rate of exergy destruction cost belongs to the gas turbine by 310558 \$/year.

The net output power system increases to approximately 4340 kW by increasing the current density and then decreases. Also, the SUCP of the system decreases at the approximate current density of 14143 and then increases.

The SUCP of the system increases to approximately 9420 \$/GJ at PR=12 and then decreases with the increment of the compressor ratio.

By increasing the inlet temperature of the fuel cell, the SOFC voltage at the approximate temperature of 679 K reaches the maximum value and then decreases; as a result, the energy and exergy efficiencies increase to the highest point and then drop. Also, the SUCP of the system reaches the minimum amount of 9240 \$/GJ and then increases.

References

- [1] H. Rostamzadeh, M. Ebadollahi, H. Ghaebi, A. Shokri, Comparative study of two novel micro-CCHP systems based on organic Rankine cycle and Kalina cycle, *Energy conversion and management*, 183 (2019) 210-229.
- [2] F. Ranjbar, A. Chitsaz, S. Mahmoudi, S. Khalilarya, M.A. Rosen, Energy and exergy assessments of a novel trigeneration system based on a solid oxide fuel cell, *Energy Conversion and Management*, 87 (2014) 318-327.
- [3] L. Khani, S.M.S. Mahmoudi, A. Chitsaz, M.A. Rosen, Energy and exergoeconomic evaluation of a new power/cooling cogeneration system based on a solid oxide fuel cell, *Energy*, 94 (2016) 64-77.
- [4] S. Campanari, L. Mastropasqua, M. Gazzani, P. Chiesa, M.C. Romano, Predicting the ultimate potential of natural gas SOFC power cycles with CO₂ capture—Part A: Methodology and reference cases, *Journal of Power Sources*, 324 (2016) 598-614.
- [5] M.M. Whiston, W.O. Collinge, M.M. Bilec, L.A.

- Schaefer, Exergy and economic comparison between kW-scale hybrid and stand-alone solid oxide fuel cell systems, *Journal of Power Sources*, 353 (2017) 152-166.
- [6] F. Cipiti, O. Barbera, N. Briguglio, G. Giacoppo, C. Italiano, A. Vita, Design of a biogas steam reforming reactor: A modelling and experimental approach, *international journal of hydrogen energy*, 41(27) (2016) 11577-11583.
- [7] A.M. Lavasani, H. Ghaebi, Economic and thermodynamic evaluation of a new solid oxide fuel cell based polygeneration system, *Energy*, 175 (2019) 515-533.
- [8] S. Ma, J. Wang, Z. Yan, Y. Dai, B. Lu, Thermodynamic analysis of a new combined cooling, heat and power system driven by solid oxide fuel cell based on ammonia–water mixture, *Journal of power sources*, 196(20) (2011) 8463-8471.

HOW TO CITE THIS ARTICLE

E. Soleymani Afsooran, S. Ghavami Gargari, H. Ghaebi, S. Basiri Anzabi, Energy, Exergy and Thermo-economic Analysis of the Novel Combined Cycle of Solid Oxide Fuel Cell and Biogas Steam Reforming for Cogeneration Power and Hydrogen, Amirkabir J. Mech Eng., 54(1) (2022) 39-42.

DOI: 10.22060/mej.2021.19189.6987



